

Colebrook Volunteer Fire Department

1-4 Year Plan

1. Colebrook Center Fire House roof needs to be reshingle and new gutters installed. Roof is 30 years old. Shingles are curling.
2. Colebrook Center Fire House - Drain under tanker is caving in. Needs to be repaired or filled in by Town Crew or vendor.
- 3 Forge Fire Engine replacement for FY 2023. Truck will be 30 years old.
4. Colebrook Center FY 2024 Boiler replacement from oil to propane.
5. Hi-band radio replacement for fire apparatus and portable units, as the State is starting to switch over to the Hi-band. FY 2024
6. Forge Fire replace generator FY 2025. Old Detroit generator that has issues and the Fire House is used as an emergency shelter should be updated.